



**NOBLESVILLE FIRE DEPARTMENT
 FIRE PREVENTION BUREAU
 INSPECTION DIVISION**
 MATT MITCHELL – DIVISION CHIEF
 DARREL CROSS – FIRE INSPECTOR
 RYAN FLORA – PT FIRE INSPECTOR



<h2 style="margin: 0;">PLAN REVIEW REQUIREMENT</h2> <h3 style="margin: 0;">INTERIOR FINISHES</h3>

Design Professional for _____:

In accordance with InBC 803.5 and ASTM E 84, please provide documentation that identifies the **FLAME SPREAD** and **SMOKE-DEVELOPED INDEXES** for the following interior **Wall** and **Ceiling** finishes:

- _____
- _____
- _____

In accordance with InBC 804 and NFPA 253, please provide documentation that identifies the **CLASS (I or II)** of the following interior **Floor Finish** and **Floor Covering** materials:

- _____
- _____
- _____

Matt Mitchell, CFM
 City of Noblesville Fire Department
 Division Chief / Fire Marshal
 (317) 776-6336 Ext. 1412
mmitchell@noblesville.in.us