



**NOBLESVILLE FIRE DEPARTMENT  
FIRE PREVENTION BUREAU  
INSPECTION DIVISION**  
MATT MITCHELL – DIVISION CHIEF  
DARREL CROSS – FIRE INSPECTOR  
RYAN FLORA – PT FIRE INSPECTOR



**PLAN REVIEW REQUIREMENT  
STORAGE / MERCANTILE / FACTORY OCCUPANCIES**

Design Professional for \_\_\_\_\_:

**Please provide answers to the following *circled* questions:**

1. What materials or products will be stored in this proposed facility?
  - Please provide MSDS and quantities for all flammable & combustible liquids, gases, etc.
  - Please provide MSDS and quantities for all Level 1, 2 & 3 Aerosol Products.
2. What is the maximum storage height of these materials or products?
3. What is the method of storage?
  - Palletized
  - Solid Piled
  - Bin Boxes
  - On Shelves
  - In Racks
5. What is the intended type of packing material? Will the products be non-encapsulated or encapsulated?
6. If an automatic sprinkler system is provided, what is the intended basis for the sprinkler design as defined in NFPA 13? Please identify the hazard classification or commodity classification.
7. Are any flammable finish operations (*Spray Finishing, Powder Coating, etc.*) planned for this facility?

Matt Mitchell, CFM  
[mmitchell@noblesville.in.us](mailto:mmitchell@noblesville.in.us)  
(317) 776-6336 Ext. 1412