



**NOBLESVILLE FIRE DEPARTMENT
FIRE PREVENTION BUREAU
INSPECTION DIVISION**
MATT MITCHELL – DIVISION CHIEF
DARREL CROSS – FIRE INSPECTOR
RYAN FLORA – PT FIRE INSPECTOR



**CITY OF NOBLESVILLE FIRE
DEPARTMENT
*FIRE LANE MARKING
DETAIL***



- The *NO PARKING FIRE LANE* message shall be six (6) feet in depth from edge of pavement or curb
- The Letters shall be two (2) feet in height and a minimum of four (4) inches wide
- The *NO PARKING FIRE LANE* message shall be placed every fifty (50) feet
- The Striping shall be a minimum of four (4) inches wide @ a forty five (45) degree angle and five (5) feet on center.
- All markings shall be painted TRAFFIC YELLOW