

NOBLESVILLE FIRE DEPARTMENT



CODE ENFORCEMENT DIVISION

135 S. 9th Street • Noblesville, IN 46060

Telephone: 317-776-6336 • Fax: 317-776-6376

www.cityofnoblesville.org/fire • fireinspections@noblesville.in.us

Display of Highly Combustible Goods and Liquid & Gas Fueled Vehicles Indoors

Due to the extra hazards of maintaining highly combustible goods and vehicles indoors, there are extra requirements to ensure the safety of all occupants in the building, and ensure they have the ability to exit the building safely in the event of a fire.

IFC 314.1 General. Indoor displays constructed within any occupancy shall comply with Sections 314.2 through 314.4.

IFC 314.2 Fixtures and displays. Fixtures and displays of goods for sale to the public shall be arranged so as to maintain free, immediate and unobstructed access to exits as required by Chapter 10.

IFC 314.3 Highly combustible goods. The display of highly combustible goods, including but not limited to fireworks, flammable or combustible liquids, liquefied flammable gases, oxidizing materials, pyroxylin plastics and agricultural goods, in main exit aisles, corridors, covered and open malls, or within 5 feet of entrances to exits and exterior exit doors is prohibited when a fire involving such goods would rapidly prevent or obstruct egress.

IFC 314.4 Vehicles. Liquid- or gas- fueled vehicles, boats, or other motorcraft shall not be located indoors except as follows:

1. Batteries are disconnected.
2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19 L) (whichever is least).
3. Fuel tanks and fill openings are closed and sealed to prevent tampering.
4. Vehicles, boats or other motorcraft equipment are not fueled or defueled within the building.

I certify that all highly combustible goods, and liquid and gas fueled vehicles displayed indoors comply with the above requirements.

Business Name: _____

Business Address: _____

Signature/Printed Name: _____ / _____

Date of Signature: _____